



DISTRICT WATER TESTING LABORETORY

P.H.E. DIVISION, KORBA (C.G.)

(NATIONAL DRINKING WATER MISSION)

S No. - 86

Village - Dipka

Block - Katghora

District - Korba

Particulars of Sample

Details of Source & Location

Sample ID. - 854-908-052026

(i) Date of Collection - 18.05.2026

(i) Indus Public School, Dipka

(ii) Date of Sample Receive in Lab - 18.05.2026

(iii) Date of Analysis - 18.05.2026

(ii) Reference (If Any) - Sample submit

by - Shri Dr. Sanjay Gupta (Principal), Dipka

S.No	PARAMETERS	UNIT	ACCEPTABLE	CAUSE FOR REJECTION	RESULTS				
					I	II	III	IV	V
1	TEMPERATURE	°C							
2	Turbidity	NTU	5	10	0				
3	Colour	Pt. Cobalt Scale	5.0	25	--				
4	Test & Odour	--	Objectionable	Objectionable					
5	PH	Ph Scale	6.5 to 8.5	<6.5 or >9.2	6.67				
6	Conductivity	µs/cm	--	--	75.29				
7	Total (M.O.) Alkalinity	mg per ltr.	200	600	25				
8	Chlorides	mg per ltr.	200	1000	20				
9	Nitrates	mg per ltr.	10	45	-				
10	Suphates Test	mg per ltr.	200	400	-				
11	Total Hardness as CaCO ₃	mg per ltr.	200	600	30				
12	Calcium (as CaH)	mg per ltr.	75	200	20				
13	Magnesium (as MgH)	mg per ltr.	30	150	10				
14	Total dissolved Solids	mg per ltr.	500	1500	32.87				
15	Iron	mg per ltr.	1.0	1.0	0.09				
16	Fluorides	mg per ltr.	1.0	1.5	0.03				
17	Residual free Chlorine	ppm	--	--	--				
18	Cogulant Dose	mg per ltr.	--	--	--				
19	BACTERIOLOGICAL Coliform Organisme at 37 C	MPN 100 ml.	24 Hr. 48 Hr.	H2S Vial.	-Ve				
20	Faecal Coliform Specia, Test (i) (ii)								

REMARK - Sample is fit for drinking on the basis of above parameters.

Note :- Valid for 06 month from date of issue

Lab Assistant
D.W.T. Lab
Korba (C.G.)

Chemist
D.W.T. Lab
Korba (C.G.)

Assistant Engineer
P.H.E. Sub. Div.
Korba (C.G.)
जिला-कोरबा (छ.ग.)

MANAGER
INDUS PUBLIC SCHOOL
DIPKA, DISTT.- KORBA (C.G.)

Self attested
"Save Water Save Life"
PRINCIPAL
INDUS PUBLIC SCHOOL
DIPKA, DISTT.- KORBA (C.G.)

कार्यालय सहायक अभियंता
लोक स्वास्थ्य यांत्रिकी विभाग, उपखण्ड – कोरबा (छ.ग.)

पत्र क्रमांक...62.../स.अ./जि.ज.प.प्र./लोक स्वा.यां./उपखण्ड/कोरबा, दिनांक...19/05/2026

प्रति,

Principal
Indus Public School
Dipka, Dist - Korba


विषय :- जल परीक्षण रिपोर्ट भेजने बाबत।


संदर्भ :- आपका पत्र क्रमांक IPSD/2026/026, दिनांक 18/05/2026


---00---

विषयांतर्गत लेख है कि आपके द्वारा विकासखण्ड Katghora संस्था/फर्म/ग्राम पंचायत Indus Public School Dipka का 01 नग जल नमूना, जिला जल परीक्षण प्रयोगशाला में जाँच हेतु जमा किया गया। जिसका परीक्षण कर परीक्षण रिपोर्ट आपकी ओर आवश्यक कार्यवाही हेतु सूचनार्थ प्रेषित है।

सहपत्र :- जल परीक्षण रिपोर्ट।


सहायक अभियंता
लोक स्वास्थ्य यांत्रिकी
उपखण्ड-कोरबा (छ.ग.)


MANAGER
INDUS PUBLIC SCHOOL
DIPKA, DISTT.- KORBA (C.G.)

Self attested
PRINCIPAL
INDUS PUBLIC SCHOOL
DIPKA, DISTT.- KORBA (C.G.)


Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 28/66 (Repost bearing No./Sl.No.) Dated: 09/02/2026

It is certified that an inspection team headed by S.N. Kanwar A.E. PHED

(Name of Officers with designation) from Public Health Eng. Dept. PHED

inspected the Indus Public School, Dipka, Batari, Dist. Korba (C.G.)

(Name & Address of the school) on 06/02/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 28 dated 09/02/2026

of (PHED Lab) certified that

the Indus Public School Dipka (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 01 year

Signature with Seal: R. Kanwar

Name Assistant Engineer

Designation Public Health Engineering

Name & Address of the Officer Sub. Div. Korba (C.G.)

Public Health Engineering Depto
Sub Division - Korba

To Principal
Indus Public School

(Name & Address of the Institution)

Dipka, Batari, Dist. Korba

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

[Signature]
MANAGER
INDUS PUBLIC SCHOOL
DIPKA, DISTT.- KORBA (C.G.)

Self attested
PRINCIPAL
INDUS PUBLIC SCHOOL
DIPKA, DISTT.- KORBA (C.G.)
[Signature]